

# KENYON MUNICIPAL UTILITIES

Please call 507-789-6415 if you have any questions concerning City water.

<b>Water Softening Information</b>	Water quality is very stable from the wells in Kenyon. Laboratory tests have shown over the years very little change in the PH and hardness of the water. Following are answers to questions commonly asked by customers needing information on City water if they are installing water softeners:		
<b>Dissolved Solids</b>	338 mg/L	<b>Calcium as Ca CO3</b>	172 mg/L
<b>Total Harness as CaCO3</b>	256 mg/L	<b>Iron as FE</b>	.24 mg/L
<b>Grains of Hardness</b>	15	<b>PH</b>	7.3
		<b>Magnesium as CaCO3</b>	84 mg/L
		<b>Manganese as MN</b>	<.05 mg/L

Kenyon Municipal Utilities Commission	Operations Superintendent	Operators
Chairperson - Jim Malloy Commissioner - Jerry Houglum Commissioner - Molly Ryan	Randy Eggert - Class "C" license	John Lee - Class "D" license